

**Christian Valley Park CSD
Water Report – March 2022**

Water Plant Operation and Maintenance

1. Average flow for the month 0.234 MGD raw water was 1.9 NTU.

Water Line Repairs and Call Outs

1. 2650 Gayle – meter replacement
2. 2617 and 2560 Allen – meter replacement
3. 2825 Allen – Afterhours emergency shut down
4. 2653 CV Road – Replaced meter
5. 2555 Gayle Ln – went to replace meter, was a 1-inch, none in stock.

Miscellaneous

1. Wave Internet Project on CV Road/Stanley and Greg
 - a. Work was completed, no additional work. No incidents.
2. Landscape status
 - a. Met with landscape contractor that Don found and coordinated.
 - b. Discussed maintenance of new plants
 - c. Tree removal on north end of plant
 - d. Addition of two trees on west side behind pump station.
3. Kenneth Way Project
 - a. Letters were sent, no replies reported.
4. PCWA System Evaluation – Prepared distribution map and data to PCWA.
5. Generator Project – Provided Don estimate for preparation of contract drawings, bidding and construction management and start up.

Capital Improvements

1. Non to report

Upcoming Work

1. Filter inspections – pending.
2. Rebuild pump station piping (capital improvement project)

Storage Tank Project Update

1. Need to schedule the 12-month inspection for Tank 2 and repairs for Tank 1.
2. Discussed Tank 1 warranty with PRT. Sounds like they are for having the diver do the work when they inspect Tank