

CVPCSD Monthly Report

MARCH 2026

Daily average flow = 193 gpm

Daily Average Raw NTU = 7.4

Daily Average Finished NTU = .05

Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- Spring Clean underway. Cleaned out sediment basin and working on weeds
- Inspected sheds at CCC and Harry will be moving them up to the WTP
- Inventory list provided to CVP
- Calibrated all inline meters at the WTP

Distribution

- Leak repaired at Mary and Thomas. It was found that the last time the road was chip and sealed that the shut off valves were covered so Harry spent some time in those areas locating valves and making them accessible in case of future shut down requirements
- Investigated potential leak at 3747 Mary. Resident was insistent on water main leak but no mains in the area. Harry did advise the hillside was saturated and came down to his valley, but no water mains in the area. Tested Total chlorine and no chlorine detected suggesting not drinking water.

Summary

- PCWA has had numerous canal shut downs for maintenance and repairs which has proven to be a challenge as it takes time to get the plant rebalanced after the shutdown but no issues with water shortages.