

CVPCSD Monthly Report

September 2026

Daily average flow = 385 gpm

Daily Average Raw NTU = 1.4

Daily Average Finished NTU = .02

Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- Shed has been moved up to the WTP

Distribution

- 4161 Helen – Assisted new tenant in finding the shut off valve at their house as they didn't have water
- 6365 Barbara Ln – minor leak at the meter
- 5260 Stanley – Assisted in shutting off water for a service line leak

Summary

- Everything is running great, flows are just beginning to come down. .
- Clean up at the WTP – hanging new chemical signs and replacing sun stricken labels. Labeling tubing etc and just basic cleanup.
- Replaced backwash pump