

# CVPCSD Monthly Report

## December 2023

Daily average flow = 235 gpm

Daily Average Raw NTU = 2.25

Daily Average Finished NTU = 0.020

### Water Plant –

- Cleaned about 80% of sludge of reclaim/backwash tank over two days. Need to look at purchasing portable firehose/pump for cleaning (will get rental prices vs new\$)
- Pre hypo pump peristaltic tube failed. Replaced..
- Norris came out and performed annual service on both generators.
- Ordered Iwaki pump for SCC project. Should receive in Jan.
- Completed all 2023 regulatory sampling required by DDW/SWRCB.
  - DBP/TOC
  - General Mineral
  - General Physical
  - Inorganics
- Next year will need to sample for VOC/SOC

### Distribution –

- Completed backflow testing.
- 5 backflow failures repaired and retested.
- Completed valve exercising.

### Summary

- Reclaim sludge went well. Will get on every six month schedule (March/September). Also, will sludge sed basin in March as well.
- Would like to talk about a mobile fire pump for basin/reclaim cleaning. This would take the place of needing utility water/hydrants for a while.