

CVPCSD Monthly Report

SEPTEMBER 2025

Daily average flow = 465 gpm

Daily Average Raw NTU = 3.1

Daily Average Finished NTU = .041

Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- Generator has been repaired and runs like new, finished repairs in October.

Distribution –

- 13991 Frontier Oaks – Resident had water leak requesting shut off at meter
- 2708 Allen – Service leak, resident requesting water shut off
- 2403 Allen – Service connection leak, resident requesting water shut off

Summary

- Very quiet month with no major issues. Plant is running excellent.