

CVPCSD Monthly Report

June 2026

Daily average flow = 400 gpm

Daily Average Raw NTU = 2.2

Daily Average Finished NTU = .02

Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- The landscape guy has begun the fire mitigation cleanup in CVP. A lot has been cleaned up, and there are a lot of piles of debris all the way to the plant. Next step will be a chipper to chip everything. He also advised we will need 4-6 yards of gravel for the pot hole near the plant entrance. He will handle the delivery and disbursement.

Distribution

- 5329 Morningside – assisted the resident in a water shut off
- 5255 Thomas – report of a water main break. Minor break and Iorang assisted in the fix.
- 5207 Morningside – reported no water. Harry assisted her in locating the issue and resolved.

Summary

- The State approved the final O&M Plan so its official and in use
- We are working on the County annual CERS (California Environmental Reporting System) Report. Don't expect any issues, just an annual requirement.