

CVPCSD Monthly Report

August 2026

Daily average flow = 449 gpm

Daily Average Raw NTU = 1.3

Daily Average Finished NTU = .02

Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- Landscape guy is moving the shed up to the plant the week of September 7. He is working with Harry on location.

Distribution

- 3300 Race Circle – had a bathroom line break and needed the water shut off.
- 4940 Lauren Ct – Requested water shut off
- 2315 Ross – Water shut down for service line repairs
- 3707 Witt – Water shut down for service line repairs
- 6008 Virginia – very minor water leak at the meter. Harry checked and no leak, just damp around the valve.

Summary

- Everything is running great, flows are high but typical for summer heat.
- Fire Hydrant leak at Christian Valley and Stanley – Harry tightened it and shut it down. Speculation is someone took water from the meter.