

CVPCSD Monthly Report

MAY 2026

Daily average flow = 295 gpm

Daily Average Raw NTU = 2.1

Daily Average Finished NTU = .02

Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- Had an estimate to clean up the WTP property in terms of fire mitigation, repainting the WTP sheds where the paint is flaking off, and moving the shed up to the WTP. He has us on the schedule and starting the week of 6/22
- American River Gas filled the propane tank for the standby generator.
- Raw Water Actuator for the valve was leaking, so the compressor has to cycle a lot. We had installed a new compressor about 6 months ago and it died. Repaired on 6/22/2026.

Distribution

- 2305 Christian Valley Rd – Leak at the curb stop. Very minor, plan to replace with assistance from Lorang when we have a larger call out.
- 5251 Morningside – Shut off water at the request of Don due to lack of payment. House vacant.

Summary

- The State regulator requested an update of the O&M Manual for CVP. It hadn't been updated since 2008. Requested Gerry LaBudde's assistance on updating the technical schematics. Update currently under review by the regulator.