Christian Valley Park CSD Water Report – December 2021

Water Plant Operation and Maintenance

1. Average flow for the month 0.152 MGD raw water was 8.7 NTU.

Water Line Repairs and Call Outs

- 1. Minor service shut offs.
- 2. Patched Helen leak.

Miscellaneous

- 1. Christmas Storm
 - a. Impacts to raw water supply to WTP
- 2. Tree on northside of property
- 3. Landscape maintenance
 - **a.** Contractor to ensure proper irrigation rates
 - **b.** Replacement of tree on north side
 - c. Additional tree on west side of property for screening between Jeff's house and the plant

Capital Improvements

1. None to report

Upcoming Work

- 1. Clean sludge basin this week will shut plant down for a couple of says/.
- 2. Filter inspections pending.

Storage Tank Project Update

- 1. Working on project close out
 - a. USDA documents submitted for review 12/14; checked with USDA in Jan. Reported thumb drive didn't work. Resent via Fed Ex.
 - b. Waiting on USDA review for release of PP17
- 2. Quote for ROV for coating inspection.
- 3. Corrosion control system connection.